



# Ventilation Tradeoff Study Considering Switch to Battery Electric Vehicles (BEV)

Nathan Wineinger

Consultant (Mine Ventilation), SRK Mine Ventilation Services

Clovis, California, USA


# Introduction

- BEV study completed for a new mine in Colombia
- In response to a Feasibility Study - Scoping Study
- High ventilation power demands
- Replace diesel trucks and loaders with BEV equivalents



# Key Assumptions and Design Considerations

- BEV substitutions only considered for LHDs and Haul Trucks
- 0.06 m<sup>3</sup>/s per kW – Colombian Regulations 0.09 - 0.13 m<sup>3</sup>/s per kW
  - Variance sought for this.
  - Airflow requirements for secondary and maintenance equipment considered.
- 60-tonne diesel trucks and 18-tonne diesel LHDs used in original diesel study.
  - BEV equipment of that size do not yet exist – Assumed they would.



# Assumptions and Considerations cont.

- Potential equip. fires not considered at this stage
  - Lower airflow in mine → more significant fire effects
  - High concentrations of HF gas released




# Assumptions and Considerations cont.



- Traffic patterns and mine development schedule assumed not to change
  - Type of BEV chosen can affect mine layout
  - Regenerative braking
  - Strategic locations of charging stations
  - Scoping Level study
- Secondary ventilation – auxiliary fans and headings
  - Unchanged from diesel study – maintain blast clearing times


# Heat Generation Calculations

- Diesel Study – High heat generation – large number of equip.
- BEV study – Trucks/LHDs 1/3 of the heat of diesel equivalent.
- Assume larger not yet existing BEV equip – scale similarly
- Add in extra heat for secondary equipment -50% Truck/LHD heat of diesel models
- Additional secondary equipment not modeled – intermittent operation




# Calculations and Results

- Four Ventilation modeling stages developed based on original study.
- Original infrastructure left as is since equipment sizes assumed to be similar
- Airflow requirements primarily based on ventilating secondary equipment
- Results show reduction in required airflow of 50% with 80% reduction in power.



## Diesel Equipment vs BEV Equipment Modeling Results




\*Total of primary fans only, excludes total secondary fan motor power.



# Additional modeling stages


- With significant reduction in airflow – reduce mine infrastructure
  - Ramp, level, and drift changes based on equipment envelopes (not changed)
  - Number of raises could be reduced
  - Size of remaining raises could be reduced



# Raises Infrastructure Savings

Model Description	Total Raise Volume Saved (m <sup>3</sup> )
Original BEV equip./Diesel equip. study	--
BEV equip., optimized size of raises	10,000
BEV equip., optimized number and size of raises	110,000

## Diesel Equipment vs all BEV Equipment Modeling Results



\*Total of primary fans only, excludes total secondary fan motor power.


# Discussion of Results

- Potential for significant ventilation power cost savings
- Potential for significant reduction in size/# of raises
  - Caution – ventilation should drive production not limit it.
  - If BEV is chosen to size raises, then diesel chosen later – Undersized!
- Reduced power for ventilation, but increased power for BEVs
- Do mines have the available electrical capacity?
- Power grid strategy needs to be considered to avoid spikes in usage


# Discussion of Results cont.

- Diesel vs BEV new capital costs – BEVs cost 125% of Diesel equivalent
- Specialized mechanics, electricians, other technical staff different than needed for an all-diesel fleet.
- If battery swap-out chosen, how many swaps per shift?
  - Function of shift length, elevation changes, haul distances, etc.
- Limited data available (maintenance, longevity, reliability, dependability, etc)

# Conclusions



- Lower Ventilation CAPEX/OPEX
- Reduced ventilation airway dimensions
- Reduced/ eliminated diesel emissions from equipment



- Undersize ventilation system
- Control of gases/fires
- Heat/dust mitigation
- Higher equipment capital costs
- Specialized personnel



- Ventilation planning
- Thermal modeling
- Phased ventilation models
- Airway size sensitivity analysis
- Fire/transient time modeling
- Battery Charging Strategy

# Questions?

Nathan Wineinger

Consultant

Mine Ventilation Services,

a business unit of SRK Consulting, (U.S.), Inc.

+1 (559) 452 0182

[nwineinger@srk.com](mailto:nwineinger@srk.com)

